

मुख्य अभियंता विद्युत का कार्यालय
बीएसएनएल विद्युत महाराष्ट्र पश्चिम क्षेत्र
भूतल, बीएसएनएल प्रशासनिक भवन
जुहू तारा रोड, मुंबई



भारत संचार निगम लिमिटेड
(भारत सरकार का उपक्रम)
BHARAT SANCHAR NIGAM LIMITED
(A Govt. of India Enterprise)

पत्र संख्या: 1597/CEEM/BSNL/ 18 -हिंदी

दिनांक 14.02.2020

सेवा में,
सभी एसएसए प्रमुख
महाराष्ट्र दूरसंचार क्षेत्र,
मुंबई

विषय : एसएसए द्वारा इलेक्ट्रिसिटी बिलों का सत्यापन


संदर्भ : इलेक्ट्रिकल बिलों का एसएसए स्तर पर सत्यापन - 13 फरवरी 2020 को जारी किए गए बिल

महाराष्ट्र में बिजली के बिलों का भुगतान सर्कल ऑफिस में किया जाता है। हालाँकि यह उम्मीद की जाती है कि एसएसए स्तर में भी बिलों का सत्यापन किया जाता है और स्थानीय बिजली कार्यालयों से संपर्क करके किसी भी ओवरबिलिंग और बिलों के सुधार के मामले में किया जाता है।

उपरोक्त अवधि के दौरान देखी गई विसंगतियों को संकलित किया गया है और संबंधित क्षेत्र इकाइयों द्वारा आवश्यक कार्रवाई करने के लिए जारी किया जा रहा है।

यह गतिविधि बिजली में परिहार्य व्यय को कम करने में मदद करेगी।

जारी किए गए बिजली बिलों की देखी गई विसंगतियों संलग्न हैं


राजीव सोनी 14/02/2020

मुख्य अभियंता (विद्युत),
बीएसएनएल, मुंबई

CA No.	Name and Address	SSA	Discrepancy	Action to be taken
456030400805	THE SUB. DIVISIONAL OFF. TELEPHONE RAJURA Adresss : AT & POST-KORPANA TAL-KOR, DIST- CHANDRAPUR	CHAND RAPUR CIRCLE	Suden jump of consumption by 12,805,910.00%	1) Bldg incharge to get reasons and take corrective action. 2) Please check the meter readings of respective months.
284050338213	SHRI UP-VIBHAGIY TELEPHONE ADHIKARI Adresss : A/P NERLE C 1988 TAL WALWA DIST SANGLI	SANGLI CIRCLE	Suden jump of consumption by 62.35%	Bldg incharge to get reasons and take corrective action
284200284516	SUB DIV. ENGINEER TELEPHONE OFFICE Adresss : A/P WATEGAON C 24- 03 TAL WALWA DIST SANGLI	SANGLI CIRCLE	Suden jump of consumption by 3,964.24%	Bldg incharge to get reasons and take corrective action
396210003372	SHRI UPMANDAL ABHIGARTA BSNL TELEPHONE Adresss : POHONA AT POST POHONA	WARDH A CIRCLE	1) Suden jump of consumption by 533.67% 2) Mismatch in meter readings and meter numbers	1) Bldg incharge to get reasons and take corrective action for mismatch in meter readings. 2) Take corrective action for Jan-2020 electricity bill.
265130322216	SHRI THE SUB DIVISIOANL ENGINEER GROUP Adresss : A/P SARAWADE TAL RADHANAGARI DIST KOP	KOLHAP UR CIRCLE	1) Suden jump of consumption by 262.62% 2) Average billing is charged.	Bldg incharge to get reasons and take corrective action
450180030030	THE S.D.G.GRUP BSNL ,CHANDRAPUR Adresss : AT-PO- GHUGUS TH.DT- CHANDRAPUR	CHAND RAPUR CIRCLE	1) Suden jump of consumption by 3,912,610.00% 2) Average billing is charged.	Bldg incharge to get reasons and take corrective action

Electricity bill cases with major deficiency issued on 13 February 2020 by MSEDCL/Torrent/Goa

CA No.	Name and Address	SSA	Discrepancy	Action to be taken
60004137638	TELEPHONE EXCHANGE - - Address : POIRA BICHOLIM BICHOLIM 403504	Goa	Energy Charges Variance wrt previous month bill: 267.89%	1) Bldg incharge to check whether average units considered by GOGED is correct or not for the month of Jan-2020. 2) Whether average billed amount correctly adjusted or not for the month of Feb-2020? 3) Date of meter reading is mismatched for the month of Jan-2020 & Feb-2020, please check. 4) To take corrective action in case of any discrepancies?
60001225444	M/S. THE SUB-DIVISIONAL OFFICER Address : H.NO. KUNDAIM IND. ESTATE PONDA 403115	Goa	Energy Charges Variance wrt previous month bill: 93.14%	1) Bldg incharge to check whether average units considered by GOGED is correct or not for the month of Jan-2020. 2) Whether average billed amount correctly adjusted or not for the month of Feb-2020? 3) Date of meter reading is mismatched for the month of Jan-2020 & Feb-2020, please check. 4) To take corrective action in case of any discrepancies?
60001494156	DIVISIONAL ENGINEER TELEPHONE . Address : BOGMALO-GOA 403806	Goa	Suden jump of consumption by 82.76%	Bldg incharge to get reasons and take corrective action
60004606376	SDE (GRP) BSNL MADGAON Address : RELIANCE TRADE CENTRE, NEXT TO COLLECTOR OFF, MARGAO. 403601	Goa	Suden jump of consumption by 99.92%	Bldg incharge to get reasons and take corrective action
413250003539	SHRI THE S.D.O. BHARAT SANCHAR NIGAM Adresss : BESA KHAPARY	NAGPUR (R) CIRCLE	Actual Maximum demand is less than 10 KVA.	Tariff to get converted from 70 LT II B (20 KVA to 50 KVA) to 52 LT-II A (less than 20 KVA) on priority basis.
190551683196	SHRI SUB DIVISIONAL ENG TELE EXCHANGE Address : A/P 559/3 ANGAPUR V TAL DIS SATARA	SATARA CIRCLE	Suden jump of consumption by 2,325,000.00%	1) Bldg incharge to get reasons and take corrective action. 2) Please check wheather site is working or not? As average billing is charged every month. <i>3) site maximum demand is 161KW hence it may be converted into LT-II A.</i>